

# OFFICE OF THE FULTON COUNTY ENGINEER

9120 County Road 14  
Wauseon, Ohio 43567-9669

Telephone: 419-335-3816

[www.fultoncountyoh.com/engineer.htm](http://www.fultoncountyoh.com/engineer.htm)

Fax: 419-335-1091

---

Frank T. Onweller, P.E., P.S.  
County Engineer

Rod Creager, P.E., P.S.  
Chief Deputy Engineer

February 26, 2026

## ADDENDUM 1

Bridge 24A.9 Rehabilitation

**RE:** 3" x 9" 5-Gauge Galvanized Corrugated Decking Installation

1. The 3" x 9" 5-gauge galvanized corrugated decking shall utilize bolt down assemblies installed on opposite sides of the beam flanges in a staggered 9" spacing pattern. Welded connections are not allowed.

End of addendum.